

**RCW 70.74.330 Small arms ammunition, primers and propellants—  
Separation from flammable materials.** Small arms ammunition shall be separated from flammable liquids, flammable solids and oxidizing materials by a fire-resistant wall of one-hour rating or by a distance of twenty-five feet. [1969 ex.s. c 137 s 29.]