

RCW 70.79.270 Hydrostatic test. If at any time a hydrostatic test shall be deemed necessary to determine the safety of a boiler or unfired pressure vessel, [the] same shall be made, at the discretion of the inspector, by the owner or user thereof. [1951 c 32 s 26.]