

RCW 74.42.560 Emergency lighting for facilities housing persons with developmental disabilities. If a living unit of a facility for the developmentally disabled houses more than fifteen residents, the living unit shall have emergency lighting with automatic switches for stairs and exits. [1979 ex.s. c 211 s 56.]