

WAC 296-307-43505 Maximum capacity allowed for LP-gas installations on commercial vehicles. A single fuel container used on passenger carrying vehicles must not exceed 200 gallons water capacity.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-43505, filed 10/20/20, effective 11/20/20. WSR 97-09-013, recodified as § 296-307-43505, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-43505, filed 10/31/96, effective 12/1/96.]