

**WAC 296-835-12005 Include additional safeguards when constructing dip tanks.** (1) You must make sure the dip tank, drain boards (if provided), and supports, are made of noncombustible material.

(2) You must make sure piping connections on drains and overflow pipes allow easy access to the inside of the pipe for inspection and cleaning.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 17-18-075, § 296-835-12005, filed 9/5/17, effective 10/6/17. Statutory Authority: RCW 49.17.010, [49.17].040, and [49.17].050. WSR 02-15-102, § 296-835-12005, filed 7/17/02, effective 10/1/02.]