

WAC 296-96-02481 City of Seattle requirements for sprinklers and shunt trips. Within the city limits of Seattle application of water will be manually controlled and elevator shut down will be installed per the current code adopted by the city of Seattle elevator section.

[Statutory Authority: Chapter 70.87 RCW. WSR 18-18-070, § 296-96-02481, filed 8/31/18, effective 10/1/18; WSR 13-24-066, § 296-96-02481, filed 11/27/13, effective 1/1/14.]