

**WAC 388-847-0180 What water temperature safety measures must be met?** (1) The stabilization, assessment, and intervention (SAIF) must regulate the facility's water temperature no higher than 120 degrees Fahrenheit.

(2) SAIF must complete and document monthly water temperature checks.

[Statutory Authority: RCW 71A.12.030 and 2019 c 415 § 203(j). WSR 22-11-056, § 388-847-0180, filed 5/16/22, effective 6/16/22.]