

**WAC 51-11C-40414 Section C404.14—Demand responsive water heating.**

**C404.14 Demand responsive water heating.** Electric storage water heaters with rated water storage volume between 40 and 120 gallons and a nameplate input rating equal to or less than 12kW shall be provided with *demand responsive controls* that comply with ANSI/CTA-2045-B Level 2 or another equivalent *approved demand responsive control*.

- EXCEPTIONS:
1. Water heaters that provide a hot water delivery temperature of 180°F (82°C) or greater.
  2. Water heaters that comply with Section IV, Part HLW or Section X of the ASME Boiler and Pressure Vessel Code.
  3. Water heaters that use three-phase electric power.
  4. Storage water heaters with *demand responsive controls* that comply with ANSI/CTA 2045-A or ANSI/CTA 2045-B Level 1, that are also capable of initiating water heating to meet the temperature setpoint in response to a *demand response signal*.

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapters 19.27A and 19.27 RCW. WSR 22-14-091, 23-12-101, and 23-20-021, § 51-11C-40414, filed 7/1/22, 6/7/23, and 9/25/23, effective 3/15/24.]