

WAC 51-50-0913 Section 913—Fire pumps.

913.2.1 Protection of fire pump rooms and access. Fire pumps shall be located in rooms that are separated from all other areas of the building by 2-hour fire barriers constructed in accordance with Section 707 or 2-hour *horizontal assemblies* constructed in accordance with Section 711, or both. Fire pump rooms not directly *accessible* from the outside shall be *accessible* through an enclosed passageway from an interior exit stairway or exterior exit. The enclosed passageway shall have a *fire-resistance rating* not less than the *fire-resistance rating* of the fire pump room (see NFPA 20 Section 4.14.2.1.2).

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-0913, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-01-090, § 51-50-0913, filed 12/12/19, effective 7/1/20.]