

WAC 51-50-0918 Section 918—Emergency responder communication coverage enhancement.

918.1 General. In-building *emergency responder communication enhancement system* shall be provided in all new buildings in accordance with Section 510 of the *International Fire Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-0918, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]