

**WAC 51-51-0328 Section R328—Energy storage systems.**

**R328.2 Equipment listings.** ESS shall be *listed* and *labeled* for residential use in accordance with UL 9540.

EXCEPTIONS:

1. Where approved, repurposed unlisted battery systems from electric vehicles are allowed to be installed outdoors or in detached sheds located not less than 5 feet (1524 mm) from exterior walls, property lines, and public ways.
2. Battery systems that are an integral part of an electric vehicle are allowed provided that the installation complies with Section 625.48 of NFPA 70.
3. Battery systems less than 1 kWh (3.6 megajoules).

**R328.12 Commissioning.** ESS shall be commissioned as follows:

1. Verify that the system is installed in accordance with the approved plans and manufacturer's instructions and is operating properly.

2. Provide a copy of the manufacturer's installation, operation, maintenance, and decommissioning instructions provided with the *listed* system.

3. Provide a label on the installed system containing the contact information for the qualified maintenance and service providers.

**R328.12.1 Installation prior to closing.** Where the system is installed in a one- or two-family dwelling or townhouse unit that is owned by the builder and has yet to be sold, commissioning shall be conducted as outlined in Section R328.12, and the builder shall then transfer the required information in Section R328.12 to the homeowner when the property is transferred to the owner at the closing.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-02-058, 23-12-104, and 23-20-024, § 51-51-0328, filed 1/3/23, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-03-023, § 51-51-0328, filed 1/6/20, effective 7/1/20; WSR 16-03-025, § 51-51-0328, filed 1/11/16, effective 7/1/16. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-068, § 51-51-0328, filed 2/1/13, effective 7/1/13.]