

WAC 51-51-1413 Section M1413—Evaporative cooling equipment.

M1413.1 General. Evaporative *cooling equipment* and *appliances* shall comply with UL 1995 or UL/CSA/ANCE 60335-2-40 and shall be installed:

1. In accordance with the manufacturer's instructions.
2. On level platforms in accordance with M1305.1.3.1.
3. So that openings in exterior walls are flashed in accordance with Section R703.4.
4. So as to protect the potable water supply in accordance with Section 603 of the state plumbing code.
5. So that air intake opening locations are in accordance with Section R303.5.1.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-104, § 51-51-1413, filed 11/15/23, effective 3/16/24; WSR 16-03-025, § 51-51-1413, filed 1/11/16, effective 7/1/16.]