

WAC 51-54A-0901 General.

901.4.2 Nonrequired fire protection systems and life safety systems. A fire protection and life safety system or portion thereof not required by this code or the *International Building Code* shall be allowed to be furnished for partial or complete protection provided such installed system meets the applicable requirements of this code and the *International Building Code*. Such systems or portion of system shall be provided with signage stating "NON-REQUIRED SYSTEM." Signage shall be durable and permanent in nature, with contrasting color and background, and with lettering of not less than 1 inch (25 mm) in height. Location of such signage shall be approved.

901.8.2 Removal of existing occupant-use hose lines. The fire code official is authorized to permit the removal of existing occupant-use hose lines where all of the following conditions exist:

1. Installation is not required by this code, the *International Building Code*, or a previously approved alternative method.
2. The hose line would not be utilized by trained personnel or the fire department.
3. The remaining outlets are compatible with local fire department fittings.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-0901, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0901, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 16-03-055, § 51-54A-0901, filed 1/16/16, effective 7/1/16.]