

WAC 51-54A-1023 Section 1023—Interior exit stairways and ramps.

1023.12 Smokeproof enclosures. Where required by Section 403.5.4, 405.7.2 or 412.2.2.1, of the *International Building Code*, interior exit stairways and ramps shall be smokeproof enclosures in accordance with Section 909.20 of the *International Building Code*. Where interior exit stairways and ramps are pressurized in accordance with Section 909.20.5 of the *International Building Code*, the smoke control pressurization system shall comply with the requirements specified in Section 909.6.3 of the *International Building Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1023, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]