

WAC 246-215-06210 Cleanability—Floor and wall junctures, covered and enclosed or sealed (FDA Food Code 6-201.13). (1) In FOOD ESTABLISHMENTS in which cleaning methods other than water flushing are used for cleaning floors, the floor and wall junctures must be coved and closed to no larger than one thirty-second inch (1 mm).

(2) The floors in FOOD ESTABLISHMENTS in which water flush cleaning methods are used must be provided with drains and be graded to drain, and the floor and wall junctures must be coved and SEALED.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-06210, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-06210, filed 1/17/13, effective 5/1/13.]