

**WAC 296-150C-1195 Fire warning equipment—Automatic smoke detectors.** (1) At least one smoke detector (which may be a single station smoke detector) must be installed in each commercial coach to protect each separate bedroom. Smoke detectors must meet the requirements of the Standard for Single and Multiple Station Smoke Detectors of the Underwriters Laboratories Inc. (UL 217). All dormitories must have at least one installed smoke detector.

(2) A smoke detector must be installed in the hallway or area next to the bedroom, and must be mounted, where possible, between the commercial area and the first bedroom door on an interior wall. Where mounting cannot be achieved due to limited interior wall space, the smoke detector must be located as close as practical to the first bedroom door on an interior wall. Commercial coaches having bedrooms separated by one or a combination of common use areas (such as a kitchen, dining area, or a commercial area, but, not a bathroom) must have at least two smoke detectors, one smoke detector protecting each bedroom.

(3) Smoke detectors must be installed per their listing. The smoke detector mounting must be attached to an electrical outlet box and the detector must be permanently wired into a general purpose electrical circuit. There must be no switches in the circuits to the detectors other than the circuit breaker serving the circuits.

(4) The commercial coach manufacturer must provide a copy of the testing and maintenance instructions supplied by the manufacturer of the smoke detector for the information of the consumer and users of the commercial coach.

[Statutory Authority: RCW 43.22.340, [43.22.]355, [43.22.]360, [43.22.]432, [43.22.]440 and [43.22.]480. WSR 96-21-146, § 296-150C-1195, filed 10/23/96, effective 11/25/96.]