

WAC 296-96-05190 Pits. Lift pits shall:

- (1) Have noncombustible floors;
- (2) Be designed to prevent the entry of groundwater into the pit;
- (3) Have floors that are substantially level;
- (4) Have drains that are not directly connected to sewers;
- (5) Provide safe and convenient access to the pit;
- (6) Provide an approved ladder for pits deeper than 3 feet; and
- (7) Have nonperforated metal guards installed on the open sides of the counterweights where spring, solid or oil type buffers are attached. These guards shall:
 - (a) Extend from a point not more than 12 inches above the pit floor to a point at least 7 feet but not more than 8 feet above the floor;
 - (b) Be fastened to a properly reinforced and braced metal frame which will be at least equal in strength and stiffness to No. 14 U.S. gauge sheet steel; and
 - (c) Be omitted on the pit side where compensating chains or ropes are attached to the counterweight.

[Statutory Authority: Chapter 70.87 RCW. WSR 18-18-070, § 296-96-05190, filed 8/31/18, effective 10/1/18. Statutory Authority: RCW 70.87.020, 70.87.030, 70.87.034, 70.87.120, 70.87.185 and chapter 70.87 RCW. WSR 01-02-026, § 296-96-05190, filed 12/22/00, effective 1/22/01.]