

**WAC 296-96-24519 Hoistway and landing construction.** (1) A hoistway shall be fully enclosed, or enclosed on all landings to a height of 72 in. above the landing floor or 72 in. above the highest working level or stair level adjacent to the hoistway.

(2) Perforated enclosures may be used where fire resistance is not required. However, such enclosures shall be constructed of at least No. 13 U.S. gauge steel wire, if a steel wire grill or expanded metal grill type, and have openings that reject a 1 in. diameter ball.

(3) Adequate lighting shall be provided at each landing and in the hoistway.

Note: For purposes of this section "adequate lighting" means 5 foot-candles.

(4) Emergency evacuation ladders when installed:

(a) Shall provide access to an emergency exit.

(b) Shall be located in a position so that in an emergency a person can safely transfer from the car platform to the ladder.

Note: Transfer is considered safe when a person can maintain 3 points of contact while making the transfer.

[Statutory Authority: Chapter 70.87 RCW. WSR 18-18-070, § 296-96-24519, filed 8/31/18, effective 10/1/18.]