

WAC 388-107-0960 Plumbing—Water supply. The facility must provide the following:

(1) Water meeting the provisions of chapter 246-290 WAC, Group A public water supplies or chapter 246-291 WAC, Group B public water systems;

(2) Hot and cold water under adequate pressure readily available throughout the enhanced services facility;

(3) Labels or color codes for nonpotable water supplies as "unsafe for domestic use";

(4) Faucet controls in lavatories and sinks with:

(a) Fixtures with at least four-inch wrist blades or single-levers based on a risk assessment made by the facility;

(b) Sufficient space for full open and closed operation; and

(c) Color-coding and labels to indicate "hot" and "cold";

(5) Lavatories and sinks that have gooseneck spouts and do not have aerators in areas that require infection control; and

(6) Flush-mounted shower heads.

[Statutory Authority: RCW 70.97.230 and HCBS Final Rule 42 C.F.R. WSR 16-14-078, § 388-107-0960, filed 7/1/16, effective 8/1/16. Statutory Authority: Chapter 70.97 RCW. WSR 14-19-071, § 388-107-0960, filed 9/12/14, effective 10/13/14.]