

**WAC 388-97-4100 Mixing valves or mixing faucets in new construction.** The nursing home must provide each fixture, except toilet fixtures and special use fixtures, with hot and cold water through a mixing valve or mixing faucet.

[Statutory Authority: Chapters 18.51 and 74.42 RCW and 42 C.F.R. 489.52. WSR 08-20-062, § 388-97-4100, filed 9/24/08, effective 11/1/08.]