

**WAC 51-11C-405061 Section C405.5.1—Exterior building grounds lighting.**

**C405.5.1 Exterior building grounds lighting.** All exterior building grounds luminaires that operate at greater than 25 watts shall have a minimum efficacy of 100 lumens per watt.

- EXCEPTIONS:
1. Luminaires controlled by a motion sensor.
  2. Luminaires that qualify for one of the exceptions under Section C405.5.2.

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapters 19.27A and 19.27 RCW. WSR 22-14-091, 23-12-101, and 23-20-021, § 51-11C-405061, filed 7/1/22, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-405061, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-405061, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-405061, filed 2/1/13, effective 7/1/13.]