

**WAC 51-11R-40310 Section R403.1—Controls.**

**R403.1 Controls.** Not less than one thermostat shall be provided for each separate heating and cooling system.

**R403.1.1 Programmable or connected thermostat.** Where the primary heating system is a forced-air furnace, at least one thermostat per dwelling unit shall be Energy Star certified and capable of controlling the heating and cooling system on a daily schedule to maintain different temperature set points at different times of the day and different days of the week. The thermostat shall allow for, at a minimum, a 5-2 programmable schedule (weekdays/weekends) and be capable of providing at least two programmable setback/setup periods per day. This thermostat shall include the capability to set back, set up or temporarily operate the system to maintain zone temperatures down to 55°F (13°C) or up to 85°F (29°C). The thermostat shall be programmed initially by the manufacturer with a heating temperature set point of not greater than 70°F (21°C) and a cooling temperature set point of not less than 78°F (26°C). The thermostat and/or control system shall have an adjustable deadband of not less than 10°F.

EXCEPTIONS:

1. Systems controlled by an occupant sensor that is capable of shutting the system off when no occupant is sensed for a period of up to 30 minutes.
2. Systems controlled solely by a manually operated timer capable of operating the system for no more than two hours.
3. Ductless mini-split heat pump systems that have an integral proprietary thermostat.

**R403.1.2 Heat pump supplementary heat.** Unitary air cooled heat pumps shall include controls that minimize supplemental heat usage during start-up, set-up, and defrost conditions. These controls shall anticipate need for heat and use compression heating as the first stage of heat. Controls shall indicate when supplemental heating is being used through visual means (e.g., LED indicators). Heat pumps equipped with supplementary heaters shall be installed with controls that prevent supplemental heater operation above 40°F. At final inspection the auxiliary heat lock out control shall be set to 35°F or less.

**R403.1.3 Continuously burning pilot lights.** The natural gas systems and equipment listed below are not permitted to be equipped with continuously burning pilot lights.

1. Fan-type central furnaces.
2. Household cooking appliances.

EXCEPTION: Household cooking appliances without electrical supply voltage connections and in which each pilot light consumes less than 150 Btu/hr.

3. Pool heaters.
4. Spa heaters.
5. Fireplaces.

EXCEPTION: Any fireplace with on-demand, intermittent or interrupted ignition (as defined in ANSI Z21.20) is not considered continuous.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and chapter 19.27A RCW. WSR 23-02-060, 23-12-102, and 23-20-022, § 51-11R-40310, filed 1/3/23, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27A.045 and 19.27A.020. WSR 22-13-100, § 51-11R-40310, filed 6/14/22, effective 7/15/22. Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160 and chapter 19.27 RCW. WSR 20-01-047, § 51-11R-40310, filed 12/9/19, effective 7/1/20. Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-40310, filed 1/6/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.045 and chapters 19.27 and 34.05 RCW. WSR 13-04-055, § 51-11R-40310, filed 2/1/13, effective 7/1/13.]