

WAC 51-11R-40315 Section R403.2—Hot water boiler.

R403.2 Hot water boiler outdoor temperature setback. Hot water boilers that supply heat to the building through one- or two-pipe heating systems shall have an outdoor temperature setback control that lowers the boiler water temperature based on the outdoor temperature.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-40315, filed 1/6/16, effective 7/1/16.]