

WAC 51-11R-40520 Section R405.2—Mandatory requirements.

R405.2 Mandatory requirements. Compliance with this section requires that the mandatory provisions identified in Section R401.2 be met. All supply and return ducts not completely inside the *building thermal envelope* shall be insulated to a minimum of R-8.

[Statutory Authority: RCW 19.27A.020, 19.27A.045 and chapters 19.27 and 34.05 RCW. WSR 13-04-055, § 51-11R-40520, filed 2/1/13, effective 7/1/13.]