

**(Effective until July 1, 2023)**

**WAC 51-54A-0315 General storage.**

**Table 315.7.6(1)  
Separation Distance Between Pallet  
Stack and Building**

Wall Construction	Opening Type	Wood Pallet Separation Distance (feet)		
		≤ 50 Pallets	51 to 200 Pallets	> 200 Pallets
Masonry	None	2	2	2
Masonry	Fire-rated glazing with open sprinklers	2	5	20
Masonry	Fire-rated glazing	5	10	20
Masonry	Plain glass with open sprinklers	5	10	20
Noncombustible	None	5	10	20
Wood with open sprinklers	_____	5	10	20
Wood	None	15	30	90
Any	Plain glass	15	30	90

For SI: 1 foot = 304.8 mm

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-24-058, § 51-54A-0315, filed 11/27/19, effective 7/1/20.]

**(Effective July 1, 2023)**

**WAC 51-54A-0315 Reserved.**

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, § 51-54A-0315, filed 6/14/22, effective 7/1/23; WSR 19-24-058, § 51-54A-0315, filed 11/27/19, effective 7/1/20.]