

(Effective until July 1, 2023)

WAC 51-54A-0403 Emergency preparedness requirements.

403.3.1 Fire evacuation plan. The fire safety and evacuation plan required by Section 404 shall include a description of special staff actions. This shall include a description for stabilizing patients in a staged evacuation or full evacuation in conjunction with the entire building, if part of a multitenant facility.

403.5.4 Assembly points and fire operations. Assembly points shall not be in areas likely to be utilized for fire service operations.

403.10.2 Group R-2 occupancies. Group R-2 occupancies shall comply with Sections 403.10.2.1 through 403.10.2.4.

403.10.2.4 Group R-2 assisted living and residential care facilities. Assisted living and residential care facilities licensed by the state of Washington shall comply with Section 403.8.1 as required for Group I-1 Condition 2 occupancies.

403.10.3 Group R-4 occupancies. This section not adopted.

403.12.3 Crowd managers for gatherings exceeding 1,000 people. Where facilities or events involve a gathering of more than 1,000 people, or as required by the fire code official, crowd managers shall be provided in accordance with Sections 403.12.3.1 through 403.12.3.3.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0403, filed 1/16/16, effective 7/1/16.]

(Effective July 1, 2023)

WAC 51-54A-0403 Emergency preparedness requirements.

403.4.3 Assembly points and fire operations. Assembly points shall not be in areas likely to be utilized for fire service operations.

403.9.2 Group R-2 occupancies. Group R-2 occupancies shall comply with Sections 403.9.2.1 through 403.9.2.4.

403.9.2.4 Group R-2 assisted living and residential care facilities. Assisted living and residential care facilities licensed by the state of Washington shall comply with Section 403.7.1 as required for Group I-1 Condition 2 occupancies.

403.9.3 Group R-4 occupancies. This section not adopted.

403.10.6 Buildings with lithium-ion or lithium metal battery storage. An approved fire safety plan in accordance with Section 404 shall be prepared and maintained for buildings with lithium-ion or lithium metal battery storage.

403.11.3 Crowd managers for gatherings exceeding 1,000 people. Where facilities or events involve a gathering of more than 1,000 people, or as required by the fire code official, crowd managers shall be provided in accordance with Sections 403.11.3.1 through 403.11.3.3.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, § 51-54A-0403, filed 6/14/22, effective 7/1/23; WSR 16-03-055, § 51-54A-0403, filed 1/16/16, effective 7/1/16.]