

**WAC 51-54A-0507 Fire protection water supplies.**

**507.3 Fire flow.** Fire flow requirements for buildings or portions of buildings and facilities shall be determined by an approved method.

EXCEPTIONS:     1. Fire flow is not required for structures under 500 square feet with a B, U or R-1 occupancy where structures are at least 30 feet from any other structure and are used only for recreation.  
                  2. In rural and suburban areas in which adequate and reliable water supply systems do not exist, the fire *code official* is authorized to utilize NFPA 1142 or the *International Wildland-Urban Interface Code*.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0507, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0507, filed 2/1/13, effective 7/1/13.]