

(Effective until July 1, 2023)

WAC 51-54A-0901 General.

901.4.2 Nonrequired fire protection systems. A *fire protection system* or portion thereof not required by this code or the *International Building Code* shall be allowed to be furnished for partial or complete protection provided such installed system meets the applicable requirements of this code and the *International Building Code*. Such systems or portion of system shall be provided with signage stating "NON-REQUIRED SYSTEM." Signage shall be durable and permanent in nature, with contrasting color and background, and with lettering of not less than 1 inch in height. Location of such signage shall be approved.

901.8.2 Removal of existing occupant-use hose lines. The *fire code official* is authorized to permit the removal of existing occupant-use hose lines where all of the following conditions exist:

1. Installation is not required by this code, the *International Building Code*, or a previously approved alternative method.

2. The hose line would not be utilized by trained personnel or the fire department.

3. The remaining outlets are compatible with local fire department fittings.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-055, § 51-54A-0901, filed 1/16/16, effective 7/1/16.]

(Effective July 1, 2023)

WAC 51-54A-0901 General.

901.4.2 Nonrequired fire protection systems and life safety systems. A *fire protection* and *life safety system* or portion thereof not required by this code or the *International Building Code* shall be allowed to be furnished for partial or complete protection provided such installed system meets the applicable requirements of this code and the *International Building Code*. Such systems or portion of system shall be provided with signage stating "NON-REQUIRED SYSTEM." Signage shall be durable and permanent in nature, with contrasting color and background, and with lettering of not less than 1 inch in height. Location of such signage shall be approved.

901.8.2 Removal of existing occupant-use hose lines. The *fire code official* is authorized to permit the removal of existing occupant-use hose lines where all of the following conditions exist:

1. Installation is not required by this code, the *International Building Code*, or a previously approved alternative method.

2. The hose line would not be utilized by trained personnel or the fire department.

3. The remaining outlets are compatible with local fire department fittings.

[Statutory Authority: RCW 19.27.031 and RCW 19.27.074. WSR 22-13-093, § 51-54A-0901, filed 6/14/22, effective 7/1/23; WSR 16-03-055, § 51-54A-0901, filed 1/16/16, effective 7/1/16.]