

WAC 51-54A-0915 Carbon monoxide detection.

915.1 General. Carbon monoxide detection shall be installed in new buildings in accordance with Sections 915.1.1 through 915.6. Carbon monoxide detection shall be installed in existing buildings in accordance with Chapter 11 of the *International Fire Code*.

915.1.1 Where required. Carbon monoxide detection shall be provided in Group I and R occupancies and in classrooms in Group E occupancies in the locations specified in Section 915.2 where any of the conditions in Sections 915.1.2 through 915.1.6 exist.

EXCEPTIONS: 1. R-2 occupancies, with the exception of R-2 college dormitories, are required to install carbon monoxide detectors without exception.
2. Sleeping units or dwelling units in I and R-1 occupancies and R-2 college dormitories, hotel, DOC prisons and work releases and assisted living facilities and residential treatment facilities licensed by the state of Washington, which do not themselves contain a fuel-burning appliance, a fuel-burning fireplace, or have an attached garage, need not be provided with carbon monoxide alarms provided that they comply with the exceptions of Section 915.1.4.

915.2.1 Dwelling units. Carbon monoxide detection shall be installed outside of each separate sleeping area in the immediate vicinity of the bedrooms and on each level of the dwelling. Where a fuel-burning appliance or a fuel-burning fireplace is located within a bedroom or its attached bathroom, carbon monoxide detection shall be installed within the bedroom.

915.2.2 Sleeping units. Carbon monoxide detection shall be installed in *sleeping units*.

EXCEPTION: Carbon monoxide detection shall be allowed to be installed outside of each separate sleeping area in the immediate vicinity of the sleeping unit where the sleeping unit or its attached bathroom does not contain a fuel-burning appliance or fuel-burning fireplace and is not served by a forced air furnace.

915.2.3 Group E occupancies. When required by Section 915.1 in new buildings, or by Chapter 11 of the *International Fire Code*, carbon monoxide detection shall be installed in classrooms in Group E occupancies. Carbon monoxide alarm signals shall be automatically transmitted to an on-site location that is staffed by school personnel.

EXCEPTIONS: 1. Carbon monoxide alarm signals shall not be required to be automatically transmitted to an on-site location that is staffed by school personnel in Group E occupancies with an occupant load of 50 or less.
2. Carbon monoxide alarm signals shall not be required to be automatically transmitted to an on-site location that is staffed by school personnel in Group E occupancies where an exception contained in Section 915.1 applies, or in Group E occupancies where signals are transmitted to an off-site service monitored by a third party, such as a service that monitors fire protection systems in the building.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-162, § 51-54A-0915, filed 12/18/19, effective 7/1/20; WSR 16-03-055, § 51-54A-0915, filed 1/16/16, effective 7/1/16. Statutory Authority: RCW 19.27A.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-063, § 51-54A-0915, filed 2/1/13, effective 7/1/13.]