2515-S2.E AMS ENET S5515.1

By Senator Lovelett
[C.2]

E2SHB 2515 - S COMM AMD TO ENET COMM AMD (S-5429.1/26)
By Committee on Environment, Energy & Technology

On page 7, line 23, after "(d)" insert "Provisions requiring the facility to curtail or reduce load during an energy emergency event, including curtailing or reducing load at the request of the electric utility as informed by, but not limited to, applicable local, state, regional, and federal laws, rules, agreements, or policies; or at the request of the Bonneville power administration under the interruptible power commitments in the emergency protocols attachment for the Columbia river system water management plan;

(e)"

Reletter the remaining subsection consecutively and correct any internal references accordingly.

EFFECT: Restores the requirement for an emerging large energy use facility tariff or policy to include provisions requiring the facility to curtail or reduce load at the request of the electric utility or the Bonneville Power Administration.

--- END ---