

WAC 246-215-05280 Operation and maintenance—Scheduling inspection, testing, and service for water system device (FDA Food Code 5-205.13). A device such as a water treatment device or backflow preventer must be scheduled for inspection, testing, and service, in accordance with manufacturer's instructions and WAC 51-56-0600 and as necessary to prevent device failure based on local water conditions, and records demonstrating inspection, testing, and service must be maintained by the PERSON IN CHARGE.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-05280, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-05280, filed 1/17/13, effective 5/1/13.]