

WAC 246-359-750 Water connector to factory assembled structures (FAS). (1) A FAS with plumbing fixtures must be connected to the approved water service outlet by a flexible connector, such as copper tubing or other approved material, not less than three-fourths inch interior diameter.

(2) A separate water service shutoff valve installed on the supply side at or near the water service outlet for each FAS.

[Statutory Authority: RCW 70.114A.081. WSR 99-03-065, § 246-359-750, filed 1/18/99, effective 2/18/99.]