

**WAC 296-46B-408 Switchboards, switchgear, and panelboards.** In addition to the requirements of NEC 230.70(A), service equipment, sub-panels, and similar electrical equipment must be installed so that they are readily accessible and may not be installed in clothes closets, toilet rooms, or shower rooms.

[Statutory Authority: Chapter 19.28 RCW, RCW 19.28.031 and 19.28.251. WSR 24-05-085, § 296-46B-408, filed 2/21/24, effective 4/1/24; WSR 19-15-117, § 296-46B-408, filed 7/23/19, effective 8/23/19.]