

**WAC 296-863-30025 Service gasoline fueled PITs safely.** (1) You must handle and store liquid fuels, such as gasoline and diesel fuel, according to the National Fire Protection Association Flammable and Combustible Liquids Code (NFPA No. 30-1996).

**Note:** National Fire Protection Association codes are available by:  
Purchasing copies by writing:  
National Fire Protection Association  
1 Batterymarch Park  
Quincy, MA 02169-7471  
**OR**  
Contacting the NFPA website at [www.nfpa.org](http://www.nfpa.org).

- (2) You must stop the engine before filling a fuel tank.
- (3) You must avoid spilling fuel during servicing.
- (4) You must make sure you do **not** use open flames to check the gasoline level in fuel tanks.
- (5) You must do the following before restarting the engine after fueling:
  - (a) Put on the fuel tank cap;
  - (b) Make sure spilled oil or fuel is completely washed away or evaporated.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 17-18-075, § 296-863-30025, filed 9/5/17, effective 10/6/17; WSR 04-19-051, § 296-863-30025, filed 9/14/04, effective 2/1/05.]